



F2701.01-113-11-R0 ACOUSTICAL PERFORMANCE TEST REPORT ASTM E90

Rendered to:

Coeur d' Alene Window

SERIES/MODEL: 3821 / 5821FR

TYPE: Sliding Glass Door

Summary of Test Results				
Data File No.	Glazing (Nominal Dimensions)	STC	ΟΙΤϹ	
F2701.01C1	3/4 "IG (5/32" tempered, 7/16" air space, 5/32" tempered)	27	23	

Reference should be made to Intertek-ATI Report No. F2701.01-113-11 for complete test specimen description. This page alone is not a complete report. Flanking limit tests and reference specimen tests are available upon request.





Acoustical Performance Test Report

Coeur d' Alene Window 11420 E Montgomery Spokane Valley, Washington 99206

Report No	F2701.01-113-11
Test Date	11/09/15
Report Date	12/21/15

Project Scope

Architectural Testing, Inc., an Intertek company ("Intertek-ATI"), was contracted to conduct a sound transmission loss test. The complete test data is included as Appendix B of this report. The client provided the test specimen.

Test Methods

Testing for this project was conducted in accordance with the following standards. The equipment listed in the attachments meets the requirements of the following standards.

ASTM E90-09, Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements ASTM E413-10, Classification for Rating Sound Insulation ASTM E1332-10a, Standard Classification for Rating Outdoor-Indoor Sound Attenuation ASTM E2235-04 (2012), Standard Test Method for Determination of Decay Rates for Use in Sound Insulation Test Methods

Test Procedure

All measurements were conducted in the HT test chambers at Intertek-ATI located in York, Pennsylvania. The sensitivity of the microphones was checked before measurements were conducted.

The transmission loss values were obtained for a single direction of measurement. Two background noise sound pressure level and five sound absorption measurements were conducted at each of five microphone positions.

Two sound pressure levels were made simultaneously in the receive and source rooms at each of five microphone positions.

The air temperature and relative humidity conditions were monitored and recorded during all measurements.





Specimen Installation

A sound transmission loss test was initially performed on a filler wall.

The specimen plug was removed from the filler wall assembly. A filler wall-reducing element, consisting of two separate 2x6 wood frames used to adjust the test opening size to accommodate the test specimen. A dense neoprene gasket was placed between the two wood and concrete frames. The specimen was placed on an isolation pad in the custom test opening. Duct seal was used to seal the perimeter of the specimen to the test opening on both sides. The interior side of the specimen, when installed, was approximately 1/4" from being flush with the receive room side of the filler wall. A stethoscope was used to check for any abnormal air leaks around the test specimen prior to testing. Operable portions of the test specimen, if any, were cycled at least five times prior to testing.

Test Calculations

Transmission loss (TL) at each 1/3 octave frequency is the average source room sound pressure level minus the average receive room sound pressure level, plus, 10 times the log of the specimen area divided by the sound absorption of the receive room with the sample in place.

STC Rating

To obtain the Sound Transmission Class (STC), read the TL of the contour curve at 500 Hz. The sum of the deficiencies below the contour curve must not exceed 32. The maximum deficiency at any one frequency must not exceed 8.

OITC Rating

The Outdoor-Indoor Transmission Class (OITC) is calculated by subtracting the logarithmic summation of the TL values from the logarithmic summation of the A-weighted transportation noise spectrum stated in ASTM E1332.





Specimen Descriptions

		Frame	Fixed Panel	Active Panel
Size		78-3/4" by 78-3/4"	38-3/4" by 76-3/4"	40-1/4" by 76-1/4"
Thickness		4-1/2"	1-7/8"	1-7/8"
	Corners	Mitered	Mitered	Mitered
Fasteners		Welds Welds		Welds
Seal Method		N/A	N/A	N/A
Material		Vinyl	Vinyl	Vinyl
	Reinforcement	N/A	Steel located in meeting stile	Steel located in meeting stile
	Thermal Break Material	N/A	N/A	N/A
Daylight Opening Size		N/A	35-5/8" by 71-1/2"	35-3/4" by 71-1/2"

Glazing

Measured Overall Insulation Glass Unit Thickness	0.757"	
Spacer Type	Stainless steel	

	Exterior Sheet	Gap	Interior Sheet
Measured Thickness	0.146"	0.465"	0.146"
Muntin Pattern	N/A	N/A	N/A
Material	Tempered	Air*	Tempered
Laminate Material	N/A	N/A	N/A

Glazing Method	Exterior
Glazing Material	Foam tape
Glazing Bead Material	Vinyl

* - Stated per Client/Manufacturer, N/A-Not Applicable





Specimen Descriptions (Continued)

Components

	Туре	Quantity	Location			
Wea	Weatherstrip					
	0.167" by 0.250" Polypile with center fin	1 Row	Fixed meeting stile			
	0.167" by 0.250" Polypile with center fin	1 Row	Active top rail, bottom rail, lock stile, meeting stile			
Haro	Hardware					
	Handle and lock assembly	1	Lock stile			
	Keeper	1	Lock jamb			
	Roller wheel assembly	2	Active bottom rail			
Draiı	Drainage					
	3/4" by 1/4" Weep slot	2	Sill			

Total Weight (lbs)	Average Weight (lbs/ft ²)
202	4.69

Comments

The client did not supply a report drawing of the test specimen. Intertek-ATI will store samples of test specimens for four years.





Intertek-ATI will service this report for the entire test record retention period. Test records, such as detailed drawings, datasheets, representative samples of test specimens, or other pertinent project documentation, will be retained by Intertek-ATI for the entire test record retention period. The test record retention period ends four years after the test date.

This report does not constitute certification of this product nor an opinion or endorsement by this laboratory. It is the exclusive property of the client so named herein and relates only to the specimen tested. This report is intended to help in the client's quality assurance program, but it does not represent a continuous or exhaustive evaluation of the specimen tested or of other products or materials that were not evaluated. The statements and data provided herein do not constitute approval, disapproval, certification, or acceptance of performance or materials.

This report may not be reproduced, except in full, without the written approval of Intertek-ATI.

For INTERTEK-ATI:

Leeland S. Hoover Technician II- Acoustical Testing Todd D. Kister Laboratory Supervisor – Acoustical Testing

LSH:jmcs

Attachments (pages): This report is complete only when all attachments listed are included. Appendix A: Equipment description (1) Appendix B: Complete test results (2) Appendix C: Photographs (1)





Revision Log

<u>Rev. #</u>	Date	Page(s)	Revision(s)
RO	12/21/15	N/A	Original Report Issue

This report produced from controlled document template ATI 00280, revised 08/31/15.





Appendix A

Instrumentation:

Instrument	Manufacturer	Model	Description	ATI Number	Date of Calibration
Data Acquisition Unit	National Instruments	PXI-1033	Data Acquisition card	65127	04/14 *
Source Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64902	12/15
Source Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64903	12/15
Source Room Microphone	PCB Electronics	378B20	Microphone and Preamplifier	65103	12/15
Source Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64905	12/15
Source Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64906	12/15
Receive Room Microphone	PBC Piezotronics	378B20	Microphone and Preamplifier	64907	12/15
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64908	12/15
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64909	12/15
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	65318	10/15
Receive Room Microphone	PCB Piezotronics	378B20	Microphone and Preamplifier	64911	12/15
Receive Room Environmental Indicator	Comet	T7510	Receive Room	64915	02/15
Source Room Environmental Indicator	Comet	T7510	Source Room	64914	02/15
Microphone Calibrator	Norsonic	1251	Pistonphone Calibrator	65105	04/15

*- Note: The calibration frequency for this equipment is every two years per the manufacturer's recommendation.

Test Chamber:

	Volume	Description
Receive Room	234 m ³ (8291.3 ft ³)	Rotating vane and stationary diffusers Temperature and humidity controlled Isolation pads under the floor
Source Room	206.6 m ³ (7296.3 ft ³)	Stationary diffusers only Temperature and humidity controlled

	Maximum Size	Description	
TL Test Opening	4.27 m (14 ft) wide by	Vibratian brack between course and receive reams	
	3.05 m (10 ft) high	vibration break between source and receive rooms	

N/A-Not Applicable





Appendix B

Complete Test Results





AIRBORNE SOUND TRANSMISSION LOSS

ASTM E 90



Test Date	11/09/15									
Data File No.	F2701.01C1									
Client	Coeur d' Alene V	Window								
Description	Series/Model: 3821 / 5821FR, Sliding glass door with 3/4 " IG (5/32" tempered, 7/16" air space, 5/32" tempered)									
Specimen Area	4.00 m ²	Receive Temp.	21.1 °C		Source Temp.	21.5 °C				
Technician	Leeland S. Hoov	Receive Humidity	55%		Source Humidity	53%				

Freq	Background	Absorption	Source	Receive	Specimen	95%	Number
	SPL		SPL	SPL	TL	Confidence	of
(Hz)	(dB)	(m²)	(dB)	(dB)	(dB)	Limit	Deficiencies
80	36.7	4.6	104	86	18.1	3.49	-
100	31.4	5.3	104	78	26.2	1.64	-
125	32.8	5.4	105	79	24.3	1.58	0
160	41.1	4.9	105	80	24.1	0.72	0
200	38.8	5.0	106	86	19.3	0.93	0
250	32.8	5.5	105	87	15.9	0.82	4
315	37.6	5.6	98	82	15.3	0.67	8
400	43.2	5.6	96	73	21.4	0.28	5
500	24.1	6.2	96	70	24.2	0.44	3
630	23.9	5.9	101	72	27.3	0.15	1
800	18.3	6.0	100	68	29.8	0.22	0
1000	13.4	6.2	97	63	31.6	0.17	0
1250	13.6	6.9	97	62	33.3	0.34	0
1600	10.7	7.1	102	66	33.8	0.40	0
2000	7.3	7.3	95	57	35.2	0.24	0
2500	6.5	8.2	93	55	34.3	0.19	0
3150	6.0	9.9	95	63	28.3	0.14	3
4000	6.7	12.0	94	59	30.4	0.20	1
5000	7.5	15.3	92	52	34.8	0.29	-
STC Rating	27	(Sound Trans	mission Class)				

Deficiencies

OITC Rating

(Sound Transmission Class)

25 (Sum of Deficiencies)

23 (Outdoor-Indoor Transmission Class)

Notes:

1) Receive Room levels less than 5 dB above the Background levels are highlighted in yellow.

2) Specimen TL levels listed in red indicate the lower limit of the transmission loss.

3) Specimen TL levels listed in green indicate that there has been a filler wall correction applied





AIRBORNE SOUND TRANSMISSION LOSS

ASTM E 90



Test Date 11/09/15 Data File No. F2701.01C1 Client Coeur d' Alene Window Description Series/Model: 3821 / 5821FR, Sliding glass door with 3/4 " IG (5/32" tempered, 7/16" air space, 5/32" tempered) 4.00 m² 21.1 °C 21.5 °C Specimen Area Receive Temp. Source Temp. Technician Leeland S. Hoov Receive Humidity 55% Source Humidity 53%







Appendix C

Photographs



Receive Room View of Test Specimen



Source Room View of Test Specimen